



## LEMONT FIRE PROTECTION DISTRICT



### BUREAU OF FIRE PREVENTION

15900 New Avenue  
Lemont, IL 60439  
Business: (630) 257-0191  
Fax: (630) 257-5318  
fpb@lemontfire.com  
[lemontfire.com](http://lemontfire.com)

### LEMONT FIRE PROTECTION DISTRICT ALARM MONITORING PROTOCOL

1. This system shall be installed by a licensed fire alarm contractor per Illinois State law and a copy of their license shall be submitted to the Fire Prevention Bureau prior to installation. **225 ILCS 447**
2. A copy of the UL listing or approved agency certification for this monitoring shall be submitted to the Fire Prevention Bureau along with current contract for said service. **NFPA 72 2007 Ed. 8.3.5.**
3. Monitoring equipment specification sheets shall be submitted prior to installation. **IFC 901.2**
4. All fire alarm control equipment shall have sixty (60) hours of standby and five (5) minutes of alarm current for secondary power battery standby. **Lemont 907.1.3**
5. Any permits required by local city, village or county and must be obtained prior to installation. It is the responsibility of the fire alarm contractor to call the jurisdiction for permit verification.
6. Upon completion of installation, the system shall be tested and witnessed by the Fire Protection Bureau and possibly by jurisdiction providing permit. **IFC 901.5**
7. The code official shall be notified at least forty eight (48) hours prior to scheduling any required acceptance testing. **Lemont 901.5**
8. Upon completion of testing, a report including fire, trouble, supervisory and fail to test signals received at the supervising station shall be submitted via e-mail to [fpb@lemontfire.com](mailto:fpb@lemontfire.com). **NFPA 72 2007 Ed. 8.3.8.3, 8.5.5.1**
9. The fire alarm monitoring service shall report all fire alarm and related signals to this emergency number (630-257-2221)